



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611494

Dryden Central School

Project Name: Lead

Robert Medeiros  
P.O. Box 88  
Dryden, NY 13053

Project / PO Number: N/A  
Received: 09/29/2016  
Reported: 10/22/2016

Analytical Testing Parameters

Client Sample ID:	117 Class. Sink	Collected By:	RM-Client
Sample Matrix:	Drinking Water	Collection Date:	09/29/2016 5:33
Lab Sample ID:	J611494-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	<0.001	0.015 AL	0.001	mg/L		10/14/16 1250	10/17/16 1400

Client Sample ID:	119 Class. Sink	Collected By:	RM-Client
Sample Matrix:	Drinking Water	Collection Date:	09/29/2016 5:35
Lab Sample ID:	J611494-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	<0.001	0.015 AL	0.001	mg/L		10/14/16 1250	10/17/16 1411

Client Sample ID:	121 Class. Sink	Collected By:	RM-Client
Sample Matrix:	Drinking Water	Collection Date:	09/29/2016 5:37
Lab Sample ID:	J611494-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	<0.001	0.015 AL	0.001	mg/L		10/14/16 1250	10/17/16 1415

Client Sample ID:	123 Class. Sink	Collected By:	RM-Client
Sample Matrix:	Drinking Water	Collection Date:	09/29/2016 5:38
Lab Sample ID:	J611494-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	<0.001	0.015 AL	0.001	mg/L		10/14/16 1320	10/17/16 1419



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J611494

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level

RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division

NY Lab ID No.: 10795

New York State Department of Health

Microbac Laboratories, Inc. Dayville (NY 11549)

NY Lab ID No: 11549

New York State Department of Health

Report Comments

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.*

*Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.*

Reviewed and Approved By:

Andrew Canale  
Project Manager  
andrew.canale@microbac.com  
10/22/2016 23:54

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Dryden Elementary School	Dryden Central School District				Ice:	YES NO
Address:	36 Union Street	PO Box 88				Cooler:	YES NO
Contact:	Dryden, New York 13053	Dryden, New York 13053				Sample Temp:	
Phone:	Rob Medeiros	Rob Medeiros				Cooler Seal:	YES NO
Project:	607-280-7799	607-280-7799				Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Release to DOH: Yes						Container Material	
Email Results: Yes	imedeir1@dryden.k12.ny.us					Container Size (in MI)	
Fax Results: Yes						Preservative	
<b>Sample Information</b>		<b>Matrix</b>		<b>Number of Containers for Analysis Requested</b>		<b>Comments/Field Data</b>	
Description/Location	Date	Time	Initial	Type			
DES 071	9/29/2016	5:33A	RM				
DES 072	9/29/2016	5:35A	RM				
DES 073	9/29/2016	5:37A	RM				
DES 074	9/29/2016	5:38A	RM				
<b>Print Name and Company</b>		<b>Signature</b>		<b>Date/Time</b>		<b>Comments</b>	
Sampled:	Rob Medeiros/ Dryden Central School District		<i>[Signature]</i>		9/29/16 3:15p		
Received:			<i>[Signature]</i>		9/29/16 15:15		
Received:							
Received:							
Received:							
Received:							



J611494

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.