



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Dryden Central School

Project Name: Lead Analysis

Robert Medeiros  
P.O. Box 88  
Dryden, NY 13053

Project / PO Number: N/A  
Received: 04/01/2016 09:15  
Reported: 04/13/2016 14:46

Analytical Testing Parameters

Client Sample ID: 101 Bubbler  
Lab Sample ID: J6D0244-01  
Sample Type: Grab

Collected By: Robert Medeiros-Client  
Collection Date: 04/01/16  
Collection Time: 04:15

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	PQL	Units	Note	Prepared	Analyzed
Method: 200.8						
Lead	<0.001	0.001	mg/L		04/06/16 1303	04/08/16 0448

Analytical Testing Parameters

Client Sample ID: 102 Bubbler  
Lab Sample ID: J6D0244-02  
Sample Type: Grab

Collected By: Robert Medeiros-Client  
Collection Date: 04/01/16  
Collection Time: 04:16

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	PQL	Units	Note	Prepared	Analyzed
Method: 200.8						
Lead	<0.001	0.001	mg/L		04/06/16 1303	04/08/16 0500

Analytical Testing Parameters

Client Sample ID: 103 Bubbler  
Lab Sample ID: J6D0244-03  
Sample Type: Grab

Collected By: Robert Medeiros-Client  
Collection Date: 04/01/16  
Collection Time: 04:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	PQL	Units	Note	Prepared	Analyzed
Method: 200.8						
Lead	<0.001	0.001	mg/L		04/06/16 1312	04/08/16 0503



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 104 Bubbler
Lab Sample ID: J6D0244-04
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:19

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0507

Analytical Testing Parameters

Client Sample ID: 105 Bubbler
Lab Sample ID: J6D0244-05
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0511

Analytical Testing Parameters

Client Sample ID: 106 Bubbler
Lab Sample ID: J6D0244-06
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0514



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 107 Bubbler
Lab Sample ID: J6D0244-07
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:22

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0526

Analytical Testing Parameters

Client Sample ID: 108 Bubbler
Lab Sample ID: J6D0244-08
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:23

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0529

Analytical Testing Parameters

Client Sample ID: 109 Bubbler
Lab Sample ID: J6D0244-09
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:26

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0533



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 111 Bubbler
Lab Sample ID: J6D0244-11
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:29

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0537

Analytical Testing Parameters

Client Sample ID: 112 Bubbler
Lab Sample ID: J6D0244-12
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:30

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0541

Analytical Testing Parameters

Client Sample ID: 113 Bubbler
Lab Sample ID: J6D0244-13
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:32

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0548



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 114 Bubbler
Lab Sample ID: J6D0244-14
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:33

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0552

Analytical Testing Parameters

Client Sample ID: 115 Bubbler
Lab Sample ID: J6D0244-15
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:36

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0555

Analytical Testing Parameters

Client Sample ID: 116 Bubbler
Lab Sample ID: J6D0244-16
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:38

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0559



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 117 Bubbler
Lab Sample ID: J6D0244-17
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:39

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0610

Analytical Testing Parameters

Client Sample ID: 119 Bubbler
Lab Sample ID: J6D0244-19
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:43

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0614

Analytical Testing Parameters

Client Sample ID: 121 Bubbler
Lab Sample ID: J6D0244-21
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:46

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0618



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 123 Bubbler
Lab Sample ID: J6D0244-22
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:48

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0621

Analytical Testing Parameters

Client Sample ID: Primary Corr. Fountain, near Staff 118
Lab Sample ID: J6D0244-23
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:49

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0625

Analytical Testing Parameters

Client Sample ID: Kitchen Pre Rinse
Lab Sample ID: J6D0244-24
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:50

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1312, 04/08/16 0655



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: Kitchen 3 Bay Faucet
Lab Sample ID: J6D0244-25
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:53

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0021, 0.001, mg/L, 04/06/16 1312, 04/08/16 0658

Analytical Testing Parameters

Client Sample ID: Kitchen Rear Faucet
Lab Sample ID: J6D0244-26
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:54

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0012, 0.001, mg/L, 04/06/16 1324, 04/08/16 0702

Analytical Testing Parameters

Client Sample ID: 1st Flr. Att. Office Fountain - High Mt
Lab Sample ID: J6D0244-27
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:57

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1324, 04/08/16 0706





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 1st Flr. Att. Office Fountain - Low Mt
Lab Sample ID: J6D0244-28
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 04:59

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1324, 04/08/16 0709

Analytical Testing Parameters

Client Sample ID: CSE Office Faucet
Lab Sample ID: J6D0244-29
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:03

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.017, 0.001, mg/L, 04/06/16 1324, 04/08/16 0721

Analytical Testing Parameters

Client Sample ID: CSE Social Wkr. Faucet
Lab Sample ID: J6D0244-30
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:05

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0037, 0.001, mg/L, 04/06/16 1324, 04/08/16 0724



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 1st Flr. Fountain - Opp. A15
Lab Sample ID: J6D0244-31
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:07

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1324, 04/08/16 0728

Analytical Testing Parameters

Client Sample ID: 1st Flr. Fountain - lower 3rd Grade
Lab Sample ID: J6D0244-32
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:09

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1324, 04/08/16 0732

Analytical Testing Parameters

Client Sample ID: Nurses Office Refridge. Faucet
Lab Sample ID: J6D0244-33
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:30

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0016, 0.001, mg/L, 04/06/16 1324, 04/08/16 0743



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: Nurses Office Window Faucet
Lab Sample ID: J6D0244-34
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:32

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0013, 0.001, mg/L, 04/06/16 1324, 04/08/16 0747

Analytical Testing Parameters

Client Sample ID: Nurses Office Faucet
Lab Sample ID: J6D0244-35
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:37

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0027, 0.001, mg/L, 04/06/16 1324, 04/08/16 0750

Analytical Testing Parameters

Client Sample ID: 2nd Floor Fountain - near stairs
Lab Sample ID: J6D0244-36
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:17

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1324, 04/08/16 0754



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 3rd Floor Fountain - near stairs
Lab Sample ID: J6D0244-37
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:23

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, <0.001, 0.001, mg/L, 04/06/16 1324, 04/08/16 0805

Analytical Testing Parameters

Client Sample ID: 3rd Floor Lac Room Faucet
Lab Sample ID: J6D0244-38
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:25

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0024, 0.001, mg/L, 04/06/16 1324, 04/08/16 0809

Analytical Testing Parameters

Client Sample ID: 3rd Floor Teacher's Ctr. Faucet
Lab Sample ID: J6D0244-39
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:18

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0052, 0.001, mg/L, 04/06/16 1324, 04/08/16 0813



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6D0244

Analytical Testing Parameters

Client Sample ID: 2nd Fir Fountain By Rm. 266
Lab Sample ID: J6D0244-40
Sample Type: Grab

Collected By: Robert Medeiros-Client
Collection Date: 04/01/16
Collection Time: 05:16

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 7 columns: 200.8- ICP-MS, Result, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: 200.8, Lead, 0.0044, 0.001, mg/L, 04/06/16 1324, 04/08/16 0816

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 19.0°C

Cooler Inspection Checklist

Checklist table with 4 columns: Item, Status, Item, Status. Items include Custody Seals Intact, COC/Labels Agree, Received on Ice, Containers Intact, Preservation Correct.

Project Requested Certification(s)

Table with 2 columns: Lab/Division, State Department of Health. Rows for NY Lab ID No.: 10795 and 11549.

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale
Project Manager
04/13/2016 14:46

Go Green: Contact Andrew Canale to set up email reporting and invoicing options.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

3821 Buck Drive  
 Cortland NY 13045  
 Phone:(607)753-3403 Fax:(607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #




J6D0244

Client Information			Billing/Invoice:			Analytix Requested			Receiving Info (Lab Use Only)		
Name:	Dryden Elementary School	Dryden Central School District	PO Box 88			Ice:	YES	NO	Container Material		
Address:	36 Union Street	Dryden, New York 13053	Rob Medeiros			Cooler:	YES	NO	Container Size (in Mi)		
Contact:	Rob Medeiros	607-280-7799	607-280-7799			Sample Temp:	19.0		Preservative		
Phone:	607-280-7799					Cooler Seal:	YES	NO			
Project:						Pickup:	YES	NO			
Quote ID:						Dropoff:	C	W			
						Accepted?	YES	NO			
Rush TAT Bus. Days: < 2-5 5-7 7-10			Date Req:								
Release to DOH: Yes			ICEH@tompkins-co.org								
Email Results: Yes			rmedeir1@dryden.k12.ny.us								
Fax Results: Yes											
Sample Information						Number of Containers for Analytix Requested			Comments/Field Data		
Description/Location	Date	Time	Initial	Matrix Type							
101 Bubbler	4/1/16	4:15a	RM	DW Grab	1						MINOR SPILLAGE OVERSHOT BTL.
102 Bubbler	4/1/16	4:16a	RM	DW Grab	1						MINOR SPILLAGE OVERSHOT BTL.
103 Bubbler	4/1/16	4:17a	RM	DW Grab	1						MINOR SPILLAGE OVERSHOT BTL.
104 Bubbler	4/1/16	4:19a	RM	DW Grab	1						MINOR SPILLAGE OVERSHOT BTL.
105 Bubbler	4/1/16	4:20a	RM	DW Grab	1						MINOR SPILLAGE OVERSHOT BTL.
106 Bubbler	4/1/16	4:21a	RM	DW Grab	1						MINOR SPILLAGE OVERSHOT BTL.
107 Bubbler	4/1/16	4:22a	RM	DW Grab	1						
108 Bubbler	4/1/16	4:23a	RM	DW Grab	1						
Print Name and Company						Signature			Date/Time		
Sampled: ROB MEDEIROS. D.C.S.D						<i>[Signature]</i>			4/1/16 9:15		
Received: Catherine P. Hurst MLI						<i>[Signature]</i>			4/1/16 9:15		
Received:											
Received:											
Received:											
Received:											

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

# Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)			
Name: Dryden Elementary School		Dryden Central School District				Ice: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>			
Address: 36 Union Street		PO Box 88				Cooler: YES <input type="checkbox"/> NO <input type="checkbox"/>			
Dryden, New York 13053		Dryden, New York 13053				Sample Temp: 19.0			
Contact: Rob Medeiros		Rob Medeiros				Cooler Seal: YES <input type="checkbox"/> NO <input type="checkbox"/>			
Phone: 607-280-7799		607-280-7799				Pickup: YES <input type="checkbox"/> NO <input type="checkbox"/>			
Project:						Dropoff: C W			
Quote ID:		PO#:				Accepted? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>			
Rush TAT Bus. Days: < 2-5 5-7 7-10		Date Req:				Container Material			
Release to DOH: Yes		ICEH@tompkins-co.org				Container Size (in Ml)			
Email Results: Yes		rmedeir1@dryden.k12.ny.us				Preservative			
Fax Results: Yes						Comments/Field Data			
Sample Information				Number of Containers for Analysis Requested				Comments	
Description/Location	Date	Time	Initial	Matrix Type					
9 109 Bubbler	4/1/16	4:26a	RM	DW					
10 110 Bubbler	NOT	SAMPLED		Grab					
11 111 Bubbler	4/1/16	4:29a	RM	DW					
12 112 Bubbler	4/1/16	4:30a	RM	Grab					
13 113 Bubbler	4/1/16	4:32a	RM	DW					
14 114 Bubbler	4/1/16	4:33a	RM	Grab					
15 115 Bubbler	4/1/16	4:36a	RM	DW					
16 116 Bubbler	4/1/16	4:38a	RM	Grab					
Print Name and Company				Signature					 J6D0244
Sampled: ROB MEDEIROS D.C.S.D.				[Signature]					
Received: Catherine P. Hurst MLI				[Signature]					
Received:				Date/Time					
Received:				Date/Time					
Received:				Date/Time					
Received:				Date/Time					
Received:				Date/Time					
Received:				Date/Time					
Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.									


# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607) 753-3403 Fax: (607) 753-3415  
 NY #10795, EPA #NY00935

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Dryden Elementary School	Dryden Central School District				Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Address:	36 Union Street	PO Box 88				Cooler:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Contact:	Dryden, New York 13053	Dryden, New York 13053				Sample Temp:	19.0
Phone:	Rob Medeiros	Rob Medeiros				Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Project:	607-280-7799	607-280-7799				Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Quote ID:						Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:				Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Release to DOH: Yes	TCEH@tompkins-co.org					Container Material	
Email Results: Yes	rmedeir1@dryden.k12.ny.us					Container Size (in Mil)	
Fax Results: Yes						Preservative	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Initial	Matrix	Type	Comments/Field Data	
17 117 Bubbler	4/1/16	4:39a	RM	DW	Grab	FUTURE, MINOR DRIP	
18 118 Bubbler	NOT SAMPLED, DOES NOT EXIST						
19 119 Bubbler	4/1/16	4:42a	RM	DW	Grab		
20 120 Bubbler	NOT SAMPLED, DOES NOT EXIST						
21 121 Bubbler	4/1/16	4:46a	RM	DW	Grab		
22 123 Bubbler	4/1/16	4:46a	RM	DW	Grab		
23 Primary Corr. Fountain, near Staff 118	4/1/16	4:42a	RM	DW	Grab		
24 Kitchen Pre Rinse	4/1/16	4:50a	RM	DW	Grab	SLIGHT OVERFILL HOT/COLD SUPPLY SINGLE VALVE	
Print Name and Company				Signature		Date/Time	
Sampled: ROB MEDEIROS D.C.S.D				<i>[Signature]</i>		4/1/16 9:15A	
Received: Catherine P. Brust MCF				<i>[Signature]</i>		4/1/16 9:15	
Received:							
Received:							
Received:							
Received:							
Received:							



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.



Client Information		Billing/Invoice:	
Name:	Dryden Elementary School	Dryden Central School District	
Address:	36 Union Street	PO Box 88	
Contact:	Dryden, New York 13053	Dryden, New York 13053	
Phone:	Rob Medeiros	Rob Medeiros	
Project:	607-280-7799	607-280-7799	
Quote ID:		PO#:	
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:	
Relate to DOH: Yes	TCEH@tompkins-co.org		
Email Results: Yes	imedeir1@dryden.k12.ny.us		
Fax Results: Yes			


  

Sample Information				Matrix		Number of Containers for Analysis Requested		Analytist Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Initial	Type						Ice:	YES NO
25 Kitchen 3 Bay Faucet	4/1/16	4:53a	RM	DW	1					YES	NO
26 Kitchen Rear Faucet	4/1/16	4:57a	RM	Grab	1					YES	NO
27 1st Flr. Att. Office Fountain - High Mt	4/1/16	4:57a	RM	DW	1					YES	NO
28 1st Flr. Att. Office Fountain - Low Mt	4/1/16	4:58a	RM	Grab	1					YES	NO
29 CSE Office Faucet	4/1/16	5:03a	RM	DW	1					YES	NO
30 CSE Social Wkr. Faucet	4/1/16	5:05a	RM	Grab	1					YES	NO
31 1st Flr. Fountain - Opp. A15	4/1/16	5:07a	RM	DW	1					YES	NO
32 1st Flr. Fountain - lower 3rd Grade	4/1/16	5:09a	RM	Grab	1					YES	NO

Sample:	Print Name and Company	Signature	Date/Time
ROB MEDEIROS	D.C.S.D	<i>[Signature]</i>	4/16 2:15A
Catherine P-Hurst	MCI	<i>[Signature]</i>	4/16 9:15
Received:			
Received:			
Received:			
Received:			



J6D0244

Comments: INITIAL OVERSPOOT OF BTL. / SLAHT SPINAGE  
 INITIAL OVERSPOOT, SLAHT SPINAGE  
 204


Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoices:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Dryden Elementary School	Dryden Central School District		Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	Container Material	
Address:	36 Union Street	PO Box 88		Cooler:	YES <input type="checkbox"/> NO <input type="checkbox"/>	Container size (in MI)	
Contact:	Dryden, New York 13053	Dryden, New York 13053		Sample Temp:	19.0	Preferivative	
Phone:	Rob Medeiros	Rob Medeiros		Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>	Comments/Field Data	
Project:	607-280-7799	607-280-7799		Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>		
Quote ID:				Dropoff:	C W		
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:		Accepted?	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		
Release to DOH: Yes	TCEH@tompkins-co.org						
Email Results: Yes	rmedeir1@dryden.k12.ny.us						
Fax Results: Yes							

Sample Information				Number of Containers for Analysis Requested		Date/Time	Signature
Description/Location	Date	Time	Initial	Matrix Type			
33 Nurses Office Refrigerator. Faucet	4/1/16	5:32a	RM	DW Grab	1		
34 Nurses Office Window Faucet	4/1/16	5:32	RM	DW Grab	1		
35 Nurses Office Faucet	4/1/16	5:32a	RM	DW Grab	1		
36 2nd Flr. Fountain - near stairs	4/1/16	5:12a	RM	DW Grab	1		
37 3rd Flr. Fountain - near stairs	4/1/16	5:23a	RM	DW Grab	1		
38 3rd Flr. Lac Room Faucet	4/1/16	5:25a	RM	DW Grab	1		
39 3rd Flr. Teacher's Ctr. Faucet	4/1/16	5:18a	RM	DW Grab	1		
40 2ND FLR FOUNTAIN	4/1/16	5:16a	RM	DW Grab	1		
BY RM. 266							
Sampled:	ROB MEDEIROS	D.C.S.D.				4/1/16 9:15A	
Received:	Carthuro P. Husi	MET				4/1/16 9:15	
Received:							
Received:							
Received:							



J6D0244

2014

SIGHT OVERTHOOT OF BTL.  
 AIR IN LINES. APPEARS CAUSED REG. STAY AWAY, ZYBOK USAGE AIR IN LINES  
 BAGGED & LABELED OUT OF ORDER - MIAH FLOW.

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.