



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6C1051

Dryden Central School

Project Name: Freeville Elementary

Robert Medeiros
P.O. Box 88
Dryden, NY 13053

Project / PO Number: N/A
Received: 03/24/2016 08:59
Reported: 04/13/2016 14:48

Analytical Testing Parameters

Client Sample ID: Drinking Fountain Upper Main Corridor
Lab Sample ID: J6C1051-01
Sample Type: Grab

Collected By: RM-Client
Collection Date: 03/24/16
Collection Time: 05:47

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	<0.001		0.001	mg/L		03/28/16 1110	03/29/16 1609

Analytical Testing Parameters

Client Sample ID: Drinking Fountain Lower by Art/Music
Lab Sample ID: J6C1051-02
Sample Type: Grab

Collected By: RM-Client
Collection Date: 03/24/16
Collection Time: 05:54

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.0033		0.001	mg/L		03/28/16 1110	03/29/16 1613

Analytical Testing Parameters

Client Sample ID: Kitchen Faucet 2 Bay Sink
Lab Sample ID: J6C1051-03
Sample Type: Grab

Collected By: RM-Client
Collection Date: 03/24/16
Collection Time: 06:03

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	MCL	PQL	Units	Note	Prepared	Analyzed
Method: 200.8							
Lead	0.012		0.001	mg/L		03/28/16 1125	03/29/16 1616

Laboratory

NY: Microbac Laboratories, Inc., New York Division



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6C1051

Definitions

AL: Action Level
PQL: Practical Quantitation Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 17.6°C

Cooler Inspection Checklist

Table with 4 columns: Item, Yes, Containers Intact, Yes. Rows include Custody Seals Intact and/or No Evidence of Tampering, COC/Labels Agree, and Received on Ice (or not required).

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795 New York State Department of Health
Microbac Laboratories, Inc. Dayville (NY 11549) NY Lab ID No: 11549 New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale
Project Manager
04/13/2016 14:48

Go Green: Contact Andrew Canale to set up email reporting and invoicing options .

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	FREEVILLE ELEMENTARY	DAYDEN CSD		Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	Container Material	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Address:	43 MAIN ST	P.O. BOX 88		Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	Container Size (in MI)	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Contact:	FREEVILLE, NY 13068	DRYDEN, NY 13053		Sample Temp:	17.6	Preservative	YES <input type="checkbox"/> NO <input type="checkbox"/>
Phone:	ROB McDERROS			Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>	Comments/Field Data	
Project:	607 250-7799			Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>		
Quote ID:				Dropoff:	C W		
Rush TAT Bus. Days:	< 2-5 5-7	2-10	Date Req.:	Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		
Carbon Copy:	Yes						
Email Results:	Yes	RMEDEIRI@DAYDEN.K12.NY.US					
Fax Results:	Yes						
Sample Information				Matrix			
Description/Location	Date	Time	Initial	Type			
1 DRINKING FOUNTAIN	3/24/16	5:47a	RM		1		SLIGHT DISCOLORATION
2 UPPER MAIN CORRIDOR	3/24/16	5:54a	RM		1		TURB 1.67 NTU
3 DRINKING FOUNTAIN	3/24/16	6:03a	RM		1		SLIGHT DISCOLORATION
4 LOWER BY ART/MUSIC							TURB 1.21 NTU
5 FANUCET							V. SLIGHT DISCOLORATION
6 KITCHEN 2.00Y SINK							
7							
8							



J6C1051

Print Name and Company	Signature	Date/Time	Comments
Sampled: ROBERT MEDEROS	<i>[Signature]</i>	3/24/16 8:57	
Received: Jennifer Walker wife	<i>[Signature]</i>	3/24/16 8:57	
Received:			
Received:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.