



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Dryden Central School District

Project Name: Lead

Robert Medeiros
P.O. Box 88
Dryden, NY 13053

Project / PO Number: 17-00514
Received: 10/28/2016 11:30
Reported: 12/15/2016 08:39

Case Narrative

The Matrix Spike Duplicate performed on the following sample failed the precision criteria for Lead. The accuracy criteria were met by both the Matrix Spike and Matrix Spike Duplicate. This data is indicative of a bias related to sample matrix.

Laboratory ID: 16K1162-AM
Sample Name: J6J1610-AM (C-212 East Sink)

Analytical Testing Parameters

Client Sample ID: MS Kitchen Ice Machine
Lab Sample ID: J6J1610-01
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00539	0.015	0.00500	mg/L		12/05/16 0827	12/05/16 1424

Analytical Testing Parameters

Client Sample ID: Custodial Slop Sink
Lab Sample ID: J6J1610-02
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Metals	Result	Limit	PQL	Units	Note	Prepared	Analyzed
Method: EPA 200.8 Rev 5.4							
Lead	0.00317	0.0150	0.00100	mg/L		12/01/16 1718	12/05/16 1120



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: A Boys E Sink
Lab Sample ID: J6J1610-03
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1121

Analytical Testing Parameters

Client Sample ID: A Boys W Sink
Lab Sample ID: J6J1610-04
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1121

Analytical Testing Parameters

Client Sample ID: A Girls N Sink
Lab Sample ID: J6J1610-05
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1122



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: A Girls S Sink
Lab Sample ID: J6J1610-06
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00341, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1125

Analytical Testing Parameters

Client Sample ID: A-11 South Sink
Lab Sample ID: J6J1610-07
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1126

Analytical Testing Parameters

Client Sample ID: A-11 Center Sink
Lab Sample ID: J6J1610-08
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1127



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: A-11 North Sink
Lab Sample ID: J6J1610-09
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00239, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1127

Analytical Testing Parameters

Client Sample ID: HS Boys Locker South Sink
Lab Sample ID: J6J1610-10
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00249, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1128

Analytical Testing Parameters

Client Sample ID: HS Boys Locker North Sink
Lab Sample ID: J6J1610-11
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00164, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1130



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: MS Boys Wash Fountain
Lab Sample ID: J6J1610-12
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00558, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1131

Analytical Testing Parameters

Client Sample ID: MS Girls Wash Fountain
Lab Sample ID: J6J1610-13
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00220, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1133

Analytical Testing Parameters

Client Sample ID: F-3 Sink
Lab Sample ID: J6J1610-14
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00663, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1133



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H-1 East Sink
Lab Sample ID: J6J1610-15
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1134

Analytical Testing Parameters

Client Sample ID: H-1 Center Sink
Lab Sample ID: J6J1610-16
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1135

Analytical Testing Parameters

Client Sample ID: H-1 West Sink
Lab Sample ID: J6J1610-17
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1135



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H-2 South Sink
Lab Sample ID: J6J1610-18
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1136

Analytical Testing Parameters

Client Sample ID: H-2 North Sink
Lab Sample ID: J6J1610-19
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1137

Analytical Testing Parameters

Client Sample ID: H-2 East Sink
Lab Sample ID: J6J1610-20
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1137



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H-3 East Sink
Lab Sample ID: J6J1610-21
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1138

Analytical Testing Parameters

Client Sample ID: H-3 West Sink
Lab Sample ID: J6J1610-22
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00408, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1139

Analytical Testing Parameters

Client Sample ID: H-3 Trough East Left
Lab Sample ID: J6J1610-23
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00509, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1141



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H-3 Trough East Center Left
Lab Sample ID: J6J1610-24
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00198, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1141

Analytical Testing Parameters

Client Sample ID: H-3 trough East Center Right
Lab Sample ID: J6J1610-25
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00171, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1142

Analytical Testing Parameters

Client Sample ID: H-3 Trough East Right
Lab Sample ID: J6J1610-26
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00321, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1143



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H-3 Trough West Left
Lab Sample ID: J6J1610-27
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00212, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1143

Analytical Testing Parameters

Client Sample ID: H-3 Trough West Center Left
Lab Sample ID: J6J1610-28
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00427, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1144

Analytical Testing Parameters

Client Sample ID: H-3 Trough West Center Right
Lab Sample ID: J6J1610-29
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00162, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1145



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H-3 Trough West Right
Lab Sample ID: J6J1610-30
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00504, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1145

Analytical Testing Parameters

Client Sample ID: H Girls Wash Fountain
Lab Sample ID: J6J1610-31
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1146

Analytical Testing Parameters

Client Sample ID: H Unisex Sink
Lab Sample ID: J6J1610-32
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00120, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1147



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: H Boys Wash Fountain
Lab Sample ID: J6J1610-33
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1149

Analytical Testing Parameters

Client Sample ID: HS Nurse Toilet Sink
Lab Sample ID: J6J1610-34
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1149

Analytical Testing Parameters

Client Sample ID: HS Office Toilet Sink
Lab Sample ID: J6J1610-35
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1150



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: Aux. Gym Drink Fountain
Lab Sample ID: J6J1610-36
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1151

Analytical Testing Parameters

Client Sample ID: Aux. Gym Bottle Fill
Lab Sample ID: J6J1610-37
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 03:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1151

Analytical Testing Parameters

Client Sample ID: HS Girls Locker North
Lab Sample ID: J6J1610-38
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00314, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1152



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: HS Girls Locker South
Lab Sample ID: J6J1610-39
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00460, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1153

Analytical Testing Parameters

Client Sample ID: A-12 North Sink
Lab Sample ID: J6J1610-40
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00328, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1153

Analytical Testing Parameters

Client Sample ID: A-12 East Sink
Lab Sample ID: J6J1610-41
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0369, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1154



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: A-14 West Sink
Lab Sample ID: J6J1610-42
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00910, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1155.

Analytical Testing Parameters

Client Sample ID: A-14 East Sink
Lab Sample ID: J6J1610-43
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0259, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1157.

Analytical Testing Parameters

Client Sample ID: A-16 North West Sink
Lab Sample ID: J6J1610-44
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00178, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1157.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: A-16 North Center Sink
Lab Sample ID: J6J1610-45
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00301, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1158

Analytical Testing Parameters

Client Sample ID: A-16 North East Sink
Lab Sample ID: J6J1610-46
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00518, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1159

Analytical Testing Parameters

Client Sample ID: A-16 South Sink
Lab Sample ID: J6J1610-47
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00566, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1159



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: A-18 Sink
Lab Sample ID: J6J1610-48
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0111, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1200

Analytical Testing Parameters

Client Sample ID: MS Office Toilet Sink
Lab Sample ID: J6J1610-49
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00523, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1201

Analytical Testing Parameters

Client Sample ID: MS Nurse Toilet Sink
Lab Sample ID: J6J1610-50
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00230, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1201



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B Boys Right Sink
Lab Sample ID: J6J1610-51
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1202

Analytical Testing Parameters

Client Sample ID: B Boys Center Right Sink
Lab Sample ID: J6J1610-52
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00173, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1203

Analytical Testing Parameters

Client Sample ID: B Boys Center Left Sink
Lab Sample ID: J6J1610-53
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00142, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1205



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B Boys Left Sink
Lab Sample ID: J6J1610-54
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00187, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1205

Analytical Testing Parameters

Client Sample ID: B Girls Left Sink
Lab Sample ID: J6J1610-55
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0414, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1206

Analytical Testing Parameters

Client Sample ID: B Girls Center Left Sink
Lab Sample ID: J6J1610-56
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00119, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1207



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B Girls Center Right Sink
Lab Sample ID: J6J1610-57
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00162, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1207

Analytical Testing Parameters

Client Sample ID: B Girls Right Sink
Lab Sample ID: J6J1610-58
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00153, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1208

Analytical Testing Parameters

Client Sample ID: B South Unisex Sink
Lab Sample ID: J6J1610-59
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00103, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1208



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B North Unisex Sink
Lab Sample ID: J6J1610-60
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00415, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1209

Analytical Testing Parameters

Client Sample ID: B-13 East Left Sink
Lab Sample ID: J6J1610-61
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00178, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1212

Analytical Testing Parameters

Client Sample ID: B-13 East Center Sink
Lab Sample ID: J6J1610-62
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00150, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1213



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B-13 East Right Sink
Lab Sample ID: J6J1610-63
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00218, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1214

Analytical Testing Parameters

Client Sample ID: B-13 Teach Station
Lab Sample ID: J6J1610-64
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00185, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1214

Analytical Testing Parameters

Client Sample ID: B-17 North Sink
Lab Sample ID: J6J1610-65
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00185, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1215



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B-17 East Left Sink
Lab Sample ID: J6J1610-66
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00460, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1216

Analytical Testing Parameters

Client Sample ID: B-17 East Center Sink
Lab Sample ID: J6J1610-67
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00234, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1216

Analytical Testing Parameters

Client Sample ID: ,B-17 East Right Sink
Lab Sample ID: J6J1610-68
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00164, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1217



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B-17 Teach. Station
Lab Sample ID: J6J1610-69
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00125, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1218

Analytical Testing Parameters

Client Sample ID: B-17 Prep Sink
Lab Sample ID: J6J1610-70
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00732, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1218

Analytical Testing Parameters

Client Sample ID: B-20 West Left Sink
Lab Sample ID: J6J1610-71
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00137, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1222



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B-20 West Center Sink
Lab Sample ID: J6J1610-72
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1222

Analytical Testing Parameters

Client Sample ID: B-20 West Right Sink
Lab Sample ID: J6J1610-73
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00832, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1223

Analytical Testing Parameters

Client Sample ID: B-20 North Sink
Lab Sample ID: J6J1610-74
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00126, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1224



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: B-20 Teach. Station
Lab Sample ID: J6J1610-75
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:51

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00612, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1224

Analytical Testing Parameters

Client Sample ID: G-1 Teach. Station
Lab Sample ID: J6J1610-76
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0172, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1225

Analytical Testing Parameters

Client Sample ID: G-1 Lab Station East North
Lab Sample ID: J6J1610-77
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:54

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0284, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1226



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-1 Lab Station East Center
Lab Sample ID: J6J1610-78
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0234, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1226

Analytical Testing Parameters

Client Sample ID: G-1 Lab Station East South
Lab Sample ID: J6J1610-79
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0140, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1228

Analytical Testing Parameters

Client Sample ID: G-1 Lab Station West North
Lab Sample ID: J6J1610-80
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00787, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1229



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-1 Lab Station West Center
Lab Sample ID: J6J1610-81
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00243, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1231

Analytical Testing Parameters

Client Sample ID: G-1 Lab Station West South
Lab Sample ID: J6J1610-82
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0279, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1232

Analytical Testing Parameters

Client Sample ID: G-1 Counter West Left
Lab Sample ID: J6J1610-83
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1232



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-1 Counter West Center
Lab Sample ID: J6J1610-84
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0122, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1233

Analytical Testing Parameters

Client Sample ID: G-1 Counter West Right
Lab Sample ID: J6J1610-85
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 04:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00954, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1234

Analytical Testing Parameters

Client Sample ID: G-1 Prep
Lab Sample ID: J6J1610-86
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1234



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-3 Lab Station South West
Lab Sample ID: J6J1610-87
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0347, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1236

Analytical Testing Parameters

Client Sample ID: G-3 Lab Station South Center
Lab Sample ID: J6J1610-88
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0399, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1237

Analytical Testing Parameters

Client Sample ID: G-3 Lab Station South East
Lab Sample ID: J6J1610-89
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0237, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1238



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-3 Lab Station North West
Lab Sample ID: J6J1610-90
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0520, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1238

Analytical Testing Parameters

Client Sample ID: G-3 Lab Station North Center
Lab Sample ID: J6J1610-91
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0229, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1239

Analytical Testing Parameters

Client Sample ID: G-3 Lab Station North East
Lab Sample ID: J6J1610-92
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.0136, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1240



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-3 Counter West
Lab Sample ID: J6J1610-93
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00133, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1240.

Analytical Testing Parameters

Client Sample ID: G-4 North Right Sink
Lab Sample ID: J6J1610-94
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1241.

Analytical Testing Parameters

Client Sample ID: G-4 North Left Sink
Lab Sample ID: J6J1610-95
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1242.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-4 East Sink
Lab Sample ID: J6J1610-96
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1242

Analytical Testing Parameters

Client Sample ID: G-4 Teach. Station
Lab Sample ID: J6J1610-97
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0446, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1244

Analytical Testing Parameters

Client Sample ID: G-2 East Sink
Lab Sample ID: J6J1610-98
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1245



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G-2 South Right Sink
Lab Sample ID: J6J1610-99
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1246

Analytical Testing Parameters

Client Sample ID: G-2 South Left Sink
Lab Sample ID: J6J1610-AA
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1246

Analytical Testing Parameters

Client Sample ID: G-2 Teach. Station
Lab Sample ID: J6J1610-AB
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.0435, 0.0150, 0.00100, mg/L, G, 12/01/16 1718, 12/05/16 1248



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G 2/4 Prep
Lab Sample ID: J6J1610-AC
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00539, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1249

Analytical Testing Parameters

Client Sample ID: G Girls Wash Station
Lab Sample ID: J6J1610-AD
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1250

Analytical Testing Parameters

Client Sample ID: G Boys Wash Station
Lab Sample ID: J6J1610-AE
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00175, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1250



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: G Unisex Sink
Lab Sample ID: J6J1610-AF
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1252

Analytical Testing Parameters

Client Sample ID: C1 Boys Left Sink
Lab Sample ID: J6J1610-AG
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1253

Analytical Testing Parameters

Client Sample ID: C1 Boys Center Sink
Lab Sample ID: J6J1610-AH
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00115, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1255



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C1 Boys Right Sink
Lab Sample ID: J6J1610-AI
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00119, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1256

Analytical Testing Parameters

Client Sample ID: C1 Girls Left Sink
Lab Sample ID: J6J1610-AJ
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00123, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1256

Analytical Testing Parameters

Client Sample ID: C1 Girls Center Sink
Lab Sample ID: J6J1610-AK
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1257



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C-212 North Sink
Lab Sample ID: J6J1610-AL
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00747, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1258

Analytical Testing Parameters

Client Sample ID: C-212 East Sink
Lab Sample ID: J6J1610-AM
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00187, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1258

Analytical Testing Parameters

Client Sample ID: C-212 West Sink
Lab Sample ID: J6J1610-AN
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1302



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C2 Boys Left Sink
Lab Sample ID: J6J1610-AO
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1302

Analytical Testing Parameters

Client Sample ID: C2 Boys Center Sink
Lab Sample ID: J6J1610-AP
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1303

Analytical Testing Parameters

Client Sample ID: C2 Boys Right Sink
Lab Sample ID: J6J1610-AQ
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 05:59

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00122, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1304



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C2 Girls Left Sink
Lab Sample ID: J6J1610-AR
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00123, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1304

Analytical Testing Parameters

Client Sample ID: C2 Girls Center Sink
Lab Sample ID: J6J1610-AS
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00102, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1306

Analytical Testing Parameters

Client Sample ID: C2 Girls Right Sink
Lab Sample ID: J6J1610-AT
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1308



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: D Boys Toilet Sink
Lab Sample ID: J6J1610-AU
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00192, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1309

Analytical Testing Parameters

Client Sample ID: D Girls Toilet Sink
Lab Sample ID: J6J1610-AV
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00201, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1310

Analytical Testing Parameters

Client Sample ID: D-12 Sink
Lab Sample ID: J6J1610-AW
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00973, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1310



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: D.O. Toilet Sink
Lab Sample ID: J6J1610-AX
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.0134, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1311

Analytical Testing Parameters

Client Sample ID: Practice Field Hose Bibb
Lab Sample ID: J6J1610-AY
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00389, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1312

Analytical Testing Parameters

Client Sample ID: C-1 North Sink
Lab Sample ID: J6J1610-AZ
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00178, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1312



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C-1 South Right Sink
Lab Sample ID: J6J1610-BA
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00120, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1313

Analytical Testing Parameters

Client Sample ID: C-1 South Left Sink
Lab Sample ID: J6J1610-BB
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1316

Analytical Testing Parameters

Client Sample ID: C-1 Teach. Station
Lab Sample ID: J6J1610-BC
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00172, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1317



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C-5 South Right Sink
Lab Sample ID: J6J1610-BD
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00335, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1317

Analytical Testing Parameters

Client Sample ID: C-5 South Left Sink
Lab Sample ID: J6J1610-BE
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1318

Analytical Testing Parameters

Client Sample ID: C-5 North Sink
Lab Sample ID: J6J1610-BF
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4, Lead, 0.00240, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1319



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C-5 Teach. Station
Lab Sample ID: J6J1610-BG
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:17

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00322, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1319

Analytical Testing Parameters

Client Sample ID: C-7 North Sink
Lab Sample ID: J6J1610-BH
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1320

Analytical Testing Parameters

Client Sample ID: C-7 South Left Sink
Lab Sample ID: J6J1610-BI
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Lead, 0.00312, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1321



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Analytical Testing Parameters

Client Sample ID: C-7 South Right Sink
Lab Sample ID: J6J1610-BJ
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, 0.00339, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1321

Analytical Testing Parameters

Client Sample ID: C-7 Teach. Station
Lab Sample ID: J6J1610-BK
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1325

Analytical Testing Parameters

Client Sample ID: Transp. Drinking Fountain
Lab Sample ID: J6J1610-BL
Sample Type: Grab

Collected By: RM-Client
Collection Date: 10/21/16
Collection Time: 06:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Chicagoland

Table with 8 columns: Metals, Result, Limit, PQL, Units, Note, Prepared, Analyzed. Row 1: Method: EPA 200.8 Rev 5.4. Row 2: Lead, <0.00100, 0.0150, 0.00100, mg/L, 12/01/16 1718, 12/05/16 1325

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6J1610

Cooler Inspection Checklist

Custody Seals Intact and/or No Evidence of Tampering	Yes	Containers Intact	Yes
COC/Labels Agree	Yes	Preservation Correct (or not required)	Yes
Received on Ice (or not required)	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division	
NY Lab ID No.: 10795	New York State Department of Health
Microbac Laboratories, Inc. - Chicagoland	
NY Lab ID No: 12006	New York State Department of Health
PA DEP ID: 68-04863	Pennsylvania Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Michael Fifield For Andrew Canale
Project Manager
12/15/2016 08:39

Go Green: Contact Andrew Canale to set up email reporting and invoicing options .

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at andrew.canale@microbac.com. You may also contact Michael Fifield, Managing Director at michael.fifield@microbac.com or Robert Crookston, President at robert.crookston@microbac.com.

Client Information		Billing/Invoice:													
Name: Dryden Jr./Sr. High School	Dryden Central School District														
Address: 118 Freeville Road	PO Box 88														
Dryden, New York 13053	Dryden, New York 13053														
Contact: Rob Medeiros	Rob Medeiros														
Phone: 607-280-7799	607-280-7799														
Project:															
Quote ID:	PO#:														
Rush TAT Bus. Days: <2 2-5 5-7 7-10	Date Req.:														
Release to DOH: Yes															
Email Results: Yes	<u>medeir1@dryden.k12.ny.us</u>														
Fax Results: Yes															
Sample Information															
MS	Description/Location	Date	Time	Initial	Matrix Type	Analysis Requested				Number of Containers for Analysis Requested	Container Material	Container size(In MI)	Preservative	Comment/Field Data	
						Ice:	Cooler:	Sample Temp:	Cooler Seal:						Pickup:
050	H-1 East Sink	10/21/2016	3:34A	RM											
051	H-1 Center Sink	10/21/2016	3:35A	RM											
052	H-1 West Sink	10/21/2016	3:35A	RM											
053	H-2 South Sink	10/21/2016	3:37A	RM											
054	H-2 North Sink	10/21/2016	3:38A	RM											
055	H-2 East Sink	10/21/2016	3:38A	RM											
056	H-3 East Sink	10/21/2016	3:40A	RM											
057	H-3 West Sink	10/21/2016	3:40A	RM											
Print Name and Company						Signature		Date/Time		Comments					
Sampled: Rob Medeiros/ Dryden Central School District						<i>[Signature]</i>		10/21/16 1:30P							
Received: <i>[Signature]</i>						<i>[Signature]</i>		10/28/16 1130							
Received:															
Received:															
Received:															
Received:															

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Client Information		Billing/Invoice:	
Name: Dryden Jr./Sr. High School	Dryden Central School District		
Address: 118 Freeville Road	PO Box 88		
Contact: Dryden, New York 13053	Dryden, New York 13053		
Phone: Rob Medeiros	Rob Medeiros		
Project: 607-280-7799	607-280-7799		
Quote ID:	PO#:		
Rush TAT Bus, Days: <2 2-5 5-7 7-10	Date Req.:		
Release to DOH: Yes			
Email Results: Yes	<u>rmedeir1@dryden.k12.ny.us</u>		
Fax Results: Yes			

Sample Information				Matrix	
Description/Location	Date	Time	Initial	Type	
MS 066 "H" Girls Wash Fountain	10/21/2016	3:47A	RM		
MS 067 "H" Unisex Sink	10/21/2016	3:47A	RM		
MS 068 "H" Boys Wash Fountain	10/21/2016	3:49A	RM		
MS 069 HS Nurses Toilet Sink	10/21/2016	3:50A	RM		
MS 070 HS Office Toilet Sink	10/21/2016	3:53A	RM		
MS 071 Aux. Gym Drink Fountain	10/21/2016	3:54A	RM		
MS 072 Aux. Gym Bottle Fill	10/21/2016	3:54A	RM		
MS 073 HS Girls Locker North	10/21/2016	4:05A	RM		

Print Name and Company		Signature	Date/Time
Sampled: Rob Medeiros/ Dryden Central School District		<i>[Signature]</i>	10/21/16 11:30
Received: <i>[Signature]</i>		<i>[Signature]</i>	10/28/16 1130
Received:			
Received:			
Received:			
Received:			

Receiving Info (Lab Use Only)		Analysis Requested		Number of Containers for Analysis Requested		Comment/Field Data	
Ice: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>							
Cooler: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>							
Sample Temp: 17.3							
Cooler Seal: YES NO							
Pickup: YES NO							
Dropoff: C W							
Accepted? YES NO							
Container Material							
Container Size (in MI)							
Preservative							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:	
Name:	Dryden Jr./Sr. High School	Dryden Central School District	
Address:	118 Freeville Road	PO Box 88	
Contact:	Dryden, New York 13053	Dryden, New York 13053	
Phone:	Rob Medeiros	Rob Medeiros	
Project:	607-280-7799	607-280-7799	
Quote ID:		PO#:	
Rush TAT Bus. Days: <2 2-5 5-7 7-10	Date Req.:		
Relate to DOH: Yes			
Email Results: Yes	medeir1@dryden.k12.ny.us		
Fax Results: Yes			

Sample Information				Matrix	
Description/Location	Date	Time	Initial	Type	
MS 082	A-16 South Sink	10/21/2016	4:18A	RM	
MS 083	A-18 Sink	10/21/2016	4:20A	RM	
MS 084	MS Office Toilet Sink	10/21/2016	4:26A	RM	
MS 085	MS Nurses Toilet Sink	10/21/2016	4:28A	RM	
MS 086	"B" Boys Right Sink	10/21/2016	4:30A	RM	
MS 087	"B" Boys Ctr. Right Sink	10/21/2016	4:30A	RM	
MS 088	"B" Boys Ctr. Left Sink	10/21/2016	4:31A	RM	
MS 089	"B" Boys Left Sink	10/21/2016	4:32A	RM	

Print Name and Company		Signature	Date/Time
Sampled:	Rob Medeiros/ Dryden Central School District	<i>[Signature]</i>	10/21/16
Received:	<i>[Signature]</i>	<i>[Signature]</i>	10/28/16 1130
Received:			
Received:			
Received:			
Received:			

Receiving Info (Lab Use Only)	
Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Sample Temp:	17.3
Cooler seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Container Material	
Container Size (in MI)	
Preservative	
Comment/Field Data	

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Client Information		Billing/Invoice:	
Name:	Dryden Jr./Sr. High School	Dryden Central School District	
Address:	118 Freeville Road	PO Box 88	
Contact:	Dryden, New York 13053	Dryden, New York 13053	
Phone:	Rob Medeiros	Rob Medeiros	
Project:	607-280-7799	607-280-7799	
Quote ID:		PO#:	
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:	
Release to DOH: Yes			
Email Results: Yes	rmedeir1@dryden.k12.ny.us		
Fax Results: Yes			

Sample Information				Matrix	Analysis Requested			Receiving Info (Lab Use Only)	
MS	Description/Location	Date	Time	Type	Number of Containers for Analysis Requested	Comments/Field Data	Ice:	YES	NO
090	"B" Girls Left Sink	10/21/2016	4:33A	RM			YES	NO	
091	"B" Girls Ctr. Left Sink	10/21/2016	4:33A	RM			YES	NO	
092	"B" Girls Ctr. Right Sink	10/21/2016	4:34A	RM			YES	NO	17.3
093	"B" Girls Right Sink	10/21/2016	4:34A	RM			YES	NO	
094	"B" South Unisex Sink	10/21/2016	4:35A	RM			YES	NO	
095	"B" North Unisex Sink	10/21/2016	4:36A	RM			YES	NO	
096	B-13 East Left Sink	10/21/2016	4:38A	RM			YES	NO	
097	B-13 East Ctr. Sink	10/21/2016	4:39A	RM			YES	NO	

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Received:	Rob Medeiros/ Dryden Central School District	<i>Rob Medeiros</i>	10/28/16 11:30	
Received:	<i>M. M. M. M. M.</i>	<i>[Signature]</i>		
Received:				
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:	
Name:	Dryden Jr./Sr. High School	Dryden Central School District	
Address:	118 Freeville Road	PO Box 88	
Contact:	Dryden, New York 13053	Dryden, New York 13053	
Phone:	Rob Medeiros	Rob Medeiros	
Project:	607-280-7799	607-280-7799	
Quote ID:		PO#:	
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:	
Release to DOH: Yes			
Email Results: Yes		rmedeir1@dryden.k12.ny.us	
Fax Results: Yes			
Sample Information			
Description/Location	Date	Time	Initial
MS 106 B-17 Prep Sink	10/21/2016	4:46A	RM
MS 107 B-20 West Left Sink	10/21/2016	4:48A	RM
MS 108 B-20 West Ctr. Sink	10/21/2016	4:48A	RM
MS 109 B-20 West Right Sink	10/21/2016	4:49A	RM
MS 110 B-20 North Sink	10/21/2016	4:49A	RM
MS 111 B-20 Teach. Station	10/21/2016	4:51A	RM
MS 112 G-1 Teach. Station	10/21/2016	4:53A	RM
MS 113 G-1 Lab Station East North	10/21/2016	4:54A	RM
Print Name and Company		Signature	Date/Time
Sampled: Rob Medeiros/ Dryden Central School District		<i>Rob Medeiros</i>	10/21/16 11:20 AM
Received: mmokrzycki MLI		<i>M. Mokrzycki</i>	10/23/16 11:30
Received:			
Received:			
Received:			
Received:			
Receiving Info (Lab Use Only)		Analysis Requested	
Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		
Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		
Sample Temp:	17.3		
Cooler Seal:	YES NO		
Pickup:	YES NO		
Dropoff:	C W		
Accepted?	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>		
Container Material			
Container Size (in MI)			
Preservative			
Number of Containers for Analysis Requested		Comments/Field Data	
Lead			
P			
250			
HNO3			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:	
Name:	Dryden Jr./Sr. High School	Dryden Central School District	
Address:	118 Freeville Road	PO Box 88	
Contact:	Dryden, New York 13053	Dryden, New York 13053	
Phone:	Rob Medeiros	Rob Medeiros	
Project:	607-280-7799	607-280-7799	
Quote ID:	PO#:		
Rush TAT Bus. Days: < 2-5 5-7 7-10	Date Req:		
Release to DOH: Yes			
Email Results: Yes	rmedeir1@dryden.k12.ny.us		
Fax Results: Yes			

Sample Information				Matrix	Number of Containers for Analysis Requested	Comments/Field Data
Description/Location	Date	Time	Initial	Type		
MS 122	G-1 Prep	10/21/2016	5:00A	RM		
MS 123	G-3 Lab Station South West	10/21/2016	5:02A	RM		
MS 124	G-3 Lab Station South Ctr.	10/21/2016	5:02A	RM		
MS 125	G-3 Lab Station South East	10/21/2016	5:02A	RM		
MS 126	G-3 Lab Station North West	10/21/2016	5:05A	RM		
MS 127	G-3 Lab Station North Ctr.	10/21/2016	5:05A	RM		
MS 128	G-3 Lab Station North East	10/21/2016	5:05A	RM		
MS 129	G-3 Counter West	10/21/2016	5:06A	RM		

Sampled:	Print Name and Company	Signature	Date/Time	Comments
Sampled:	Rob Medeiros/ Dryden Central School District	<i>[Signature]</i>	10/28/16 1130	
Received:	<i>[Signature]</i>	<i>[Signature]</i>		
Received:				
Received:				
Received:				
Received:				

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Client Information		Billing/Invoice:	
Name: Dryden Jr./St. High School	Dryden Central School District	Address: 118 Freecville Road	PO Box 88
Contact: Rob Medeiros	Dryden, New York 13053	Phone: 607-280-7799	Dryden, New York 13053
Project:		PO#:	Rob Medeiros
Quote ID:		Date Req.:	607-280-7799
Rush TAT Bus. Days: <2 2-5 5-7 7-10			
Release to DOH: Yes			
Email Results: Yes	rmedeir1@dryden.k12.ny.us		
Fax Results: Yes			

Sample Information				Matrix	
Description/Location	Date	Time	Initial	Type	
MS 146	C1 Girls Left Sink	10/21/2016	5:52A	RM	
MS 147	C1 Girls Ctr. Sink	10/21/2016	5:52A	RM	
MS 148					
MS 149	C-212 North Sink	10/21/2016	5:56A	RM	
MS 150	C-212 East Sink	10/21/2016	5:57A	RM	
MS 151	C-212 West Sink	10/21/2016	5:57A	RM	
MS 152	C2 Boys Left Sink	10/21/2016	5:59A	RM	
MS 153	C2 Boys Ctr. Sink	10/21/2016	5:59A	RM	

Receiving Info (Lab Use Only)		Analysis Requested	
Ice: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>			
Cooler: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>			
Sample Temp: 17.3			
Cooler Seal: YES NO			
Pickup: YES NO			
Dropoff: C W			
Accepted? YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>			
Container Material			
Container Size (in MI)			
Preservative			
		Number of Containers for Analysis Requested	Comments/Field Data

Print Name and Company		Signature		Date/Time	
Sampled: Rob Medeiros/ Dryden Central School District		<i>[Signature]</i>		10/25/16	11:28
Received: <i>mmokrychyni MCT</i>		<i>[Signature]</i>		10/28/16	1130
Received:					
Received:					
Received:					
Received:					

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Client Information		Billing/Invoice:			
Name:	Dryden Jr./Sr. High School	Dryden Central School District			
Address:	118 Freville Road	PO Box 88			
Contact:	Dryden, New York 13053	Dryden, New York 13053			
Phone:	Rob Medeiros	Rob Medeiros			
Project:	607-280-7799	607-280-7799			
Quote ID:	PO#:				
Rush TAT Bar. Days: < 2-5	5-7	7-10	Date Req:		
Release to DOH: Yes					
Email Results: Yes	rmedeir1@dryden.k12.ny.us				
Fax Results: Yes					
Sample Information					
MS	Description/Location	Date	Time	Initial	Matrix Type
	C2 Boys Right Sink	10/21/2016	5:59A	RM	
MS 155	C2 Girls Left Sink	10/21/2016	6:01A	RM	
MS 156	C2 Girls Ctr. Sink	10/21/2016	6:01A	RM	
MS 157	C2 Girls Right Sink	10/21/2016	6:01A	RM	
MS 158	"D" Boys Toilet Sink	10/21/2016	6:06A	RM	
MS 159	"D" Girls Toilet Sink	10/21/2016	6:07A	RM	
MS 160	D-12 Sink	10/21/2016	6:08A	RM	
MS 161	D.O. Toilet Sink	10/21/2016	6:11A	RM	
Print Name and Company		Signature		Date/Time	
Sampled: Rob Medeiros/ Dryden Central School District		<i>Rob Medeiros</i>		10/21/16 11:30	
Received: <i>M. Mokrzycki</i>		<i>M. Mokrzycki</i>		10/28/16 11:30	
Received:					
Received:					
Received:					
Received:					
Comments					

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Client Information		Billing/Invoice:	
Name: Dryden Jr./Sr. High School	Dryden Central School District		
Address: 118 Freerville Road	PO Box 88		
Contact: Rob Medeiros	Dryden, New York 13053		
Phone: 607-280-7799	Rob Medeiros		
Project:	607-280-7799		
Quote ID:	PO#:		
Rush TAT Bus. Days: < 2-5 5-7 7-10	Date Req.:		
Release to DOH: Yes			
Email Results: Yes	<u>rmedeir1@dryden.k12.ny.us</u>		
Fax Results: Yes			

Sample Information					
MS	Description/Location	Date	Matrix Type		
				Time	Initial
170	C-5 Teach. Station	10/21/2016	RM	6:17A	RM
171	C-7 North Sink	10/21/2016	RM	6:22A	RM
172	C-7 South Left Sink	10/21/2016	RM	6:23A	RM
173	C-7 South Right Sink	10/21/2016	RM	6:23A	RM
174	C-7 Teach. Station	10/21/2016	RM	6:24A	RM
175	Transp. Drink Fountain	10/21/2016	RM	6:44A	RM
176					
177					

Analysis Requested		Receiving Info (Lab Use Only)	
Lead		Ice: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	
P		Cooler: YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	
250		Sample Temp: 17.3	
HNO3		Cooler Seal: YES NO	
		Pickup: YES NO	
		Dropoff: C W	
		Accepted? YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	
		Container Material	
		Container Size (in MI)	
		Preservative	
		Comments/Field Data	

Print Name and Company		Signature	Date/Time
Sampled: Rob Medeiros/ Dryden Central School District		<i>[Signature]</i>	10/28/16 11:30A
Received: <i>[Signature]</i>			10/28/16 11:30
Received:			
Received:			
Received:			
Received:			

*Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.*